

Public Notification

Highland Water District received a notice from the Washington State Department of Health, Office of Drinking Water. *Water Quality Monitoring and Reporting Violation, HIGHLAND WATER DISTRICT, PWS ID# 32850J, Snohomish County.*

The District is required to monitor quarterly for Disinfected By-Products (DBP), THHMs and HAA5s. The District didn't meet the 2nd quarter of 2026, March through June. Samples were taken on June 29th and received by the accredited lab on June 30 but were rejected for being too warm on arrival. The lab called the District on July 2nd stating the DBP were rejected. The District resubmitted new DBP samples on July 6th. The DBP samples passed. Highland Water District has been taking DBP samples on a regular bases since November 2005 and has never failed in any DBP sampling.